

From: [Roger Goodwin](#)
To: [Robert Rivera](#)
Cc: [Amanda Grisko](#); [Barret Doe](#); [john chambers](#); [Joseph Palazzolo](#)
Subject: Polymer test
Date: Wednesday, June 28, 2017 3:15:23 PM
Attachments: [Belt Press Performance 6-27-2017.xls](#)

Robert,

The polymer test were completed today. Even though Sterling had a lower unit price Fort Bend had the lowest overall operational cost in actual polymer cost per ton of sludge. Fort Bend also out performed Sterling in % solids. Sterling failed to get over 17%. Award the bid to Fort Bend our current supplier. Our guys did a great job on the testing.

Thanks

Roger Goodwin
City of New Port Richey
Water Pollution Control
Operations Manager
727-841-4568

Under Florida law, e-mail addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact this office by phone or in writing.