

**City of New Port Richey WWTP
Test Sheet**

Date	Feed	Feed	Run	Feed	Polymer	Polymer	Dry Sludge	Dry Sludge	Poly.	Dewatered	Fort Bend	
April	Gallons	%solids	Time	GPM	Gal.	Pounds/Ton	Pounds/Hr	Pounds	Cost/Ton	% Solids	% solids pre test	17.00
1	7515	1.31	0.75	167	1.16	24	1095	821	\$26.50	16.31	Fort Bend	
2	7515	1.31	0.75	167	1.16	24	1095	821	\$26.50	15.65	% solids post test	17.04
3	6750	1.31	0.75	150	1.16	27	983	737	\$29.50	16.39		
4	6750	1.31	0.75	150	1.25	29	983	737	\$31.86	16.83	Fort Bend	
5											Poly.	
6											Cost/Ton	\$26.70 at 17.04% solids
7												
8											Sterling	
9											Poly.	
10											Cost/Ton	\$31.86 at 16.83% solids
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
AVG.	7132.5	1.31	0.75	158.5	1.18	26.14	1039.01	779.25	\$28.59	16.30		