

**City of New Port Richey WWTP
Test Sheet**

Date	Feed	Feed	Run	Feed	Polymer	Polymer	Dry Sludge	Dry Sludge	Poly.	Dewatered	Fort Bend	
April	Gallons	%solids	Time	GPM	Gal.	Pounds/Ton	Pounds/Hr	Pounds	Cost/Ton	% Solids	% solids pre test	17.00
1	7515	1.31	0.75	167	1.16	24	1095	821	\$26.50	16.31	Fort Bend	
2	7515	1.31	0.75	167	1.16	24	1095	821	\$26.50	15.65	% solids post test	17.04
3	6750	1.31	0.75	150	1.16	27	983	737	\$29.50	16.39		
4	6750	1.31	0.75	150	1.25	29	983	737	\$31.86	16.83	Fort Bend	
5											Poly.	
6											Cost/Ton	\$26.70 at 17.04% solids
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
AVG.	7132.5	1.31	0.75	158.5	1.18	26.14	1039.01	779.25	\$28.59	16.30		