

# 2020 Grand Blvd Stormwater System Improvements



Remove existing 18"x24" ERCP & replace with 40' of 38"x60" ERCP

Remove existing retaining wall  
Construct 38"x60" Elliptical Mitered End Section  
Lay 116' of 38"x60" ERCP





Remove existing 18" RCP & replace with 64' of 38"x60" ERCP

Remove existing north-south headwall  
Construct 38"x60" pour "in place" headwall

Remove 8' of existing 8" VCP  
sanitary sewer gravity line  
and replace with 8" PVC

Remove & replace inlet

### Legend

-  Stormwater Pipe
-  Gravity Sewer Line
-  Stormwater Inlet
-  Elliptical Mitered End Section